

DUMPS ARENA

BICSI Installer 2 - Copper Exam

BICSI INSTC V7

Version Demo

Total Demo Questions: 10

Total Premium Questions: 116

Buy Premium PDF

<https://dumpsarena.co>

sales@dumpsarena.co

sales@dumpsarena.co
dumpsarena.co

QUESTION NO: 1

Electrical power (P) is measured in ?

- A. Ohms
- B. Farads
- C. henries
- D. Watts

ANSWER: D

QUESTION NO: 2

Which of the following fire-ratings provides information about smoke leakage?

- A. L rating
- B. I rating
- C. E rating
- D. W rating

ANSWER: A

QUESTION NO: 3

Which of the following is the first step of the emergency rescue process?

- A. Survey the scene
- B. Contact 911
- C. Notify someone
- D. Secure the area

ANSWER: A

QUESTION NO: 4

Which of the following is a floor serving space that serves as a point of termination for horizontal and backbone cables?

- A. EF
- B. TR
- C. ER
- D. Work area

ANSWER: B**QUESTION NO: 5**

A third 90-degree bend may be permitted in a conduit run if one of the bends is located within of the cable feed end?

- A. 300 mm (12")
- B. 375 mm (15")
- C. 450 mm (18")
- D. 483mm (19")

ANSWER: A**QUESTION NO: 6**

Which of the following steps should be performed first when terminating a coaxial cable?

- A. Verify connector type
- B. Cut the cable
- C. Strip the cable
- D. Fold back the braiding

ANSWER: A

QUESTION NO: 7

What is the bend radius requirement for optical fiber cable when the cable is at rest?

- A. 10 times the cables outside diameter
- B. 15 times the cables outside diameter
- C. 20 times the cables outside diameter

ANSWER: A

QUESTION NO: 8

Which of the following is the primary benefit of using wall-mounted racks and cabinets in place of traditional equipment racks?

- A. Provides equipment with a higher level of protection
- B. Allows for the equipment to be easily rearranged
- C. Optimizes airflow within the equipment room
- D. Takes up less space within the equipment room

ANSWER: D

QUESTION NO: 9

What is the recommended minimum amount of aisle space between and around equipment?

- A. 0.6 m (2')
- B. 1 m (3.3')
- C. 1.2 m (4')
- D. 1.52 m (5')

ANSWER: B

QUESTION NO: 10

A third 90-degree bend may be permitted in a conduit run if the run does NOT exceed ?

- A. 5 m (16.5')
- B. 10 m (33')
- C. 15 m (50')
- D. 30 m (100')

ANSWER: B